

Map ID
Direction
Distance
Elevation

MAP FINDINGS

EDR ID Number
EPA ID Number

633
NNE
1/2-1
0.934 mi.
4932 ft.

LEAKING AERIAL XFMR 3350
IN FRONT OF 437 LAKE STREET
BROOKLYN, NY

NY Spills S109061121
N/A

Relative:
Higher

Actual:
15 ft.

SPILLS:

Name: LEAKING AERIAL XFMR 3350
Address: IN FRONT OF 437 LAKE STREET
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 0713793 / 2008-05-12
Facility ID: 0713793
Facility Type: ER
DER Facility ID: 345134
Site ID: 395611
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2008-03-29
Investigator: gdbreen
Referred To: Not reported
Reported to Dept: 2008-03-29
CID: 41

Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: Not reported
Remediation Phase: 0
Date Entered In Computer: 2008-03-29
Spill Record Last Update: 2008-05-12
Spiller Name: Not reported
Spiller Company: CON EDISON
Spiller Address: Not reported
Spiller Company: 999
Contact Name: ERT DESK
DEC Memo: "05/12/08 - See eDocs for Con Ed report detailing cleanup and closure. 210603. see eDocs"

Remarks: "2 qts on sidewalk - on going leak a drop every half hour on concrete and asphalt - cleanup in progress - ref # 210603"

All Materials:

Site ID: 395611
Operable Unit ID: 1152553
Operable Unit: 01
Material ID: 2143332
Material Code: 0020A
Material Name: transformer oil
Case No.: Not reported
Material FA: Petroleum
Quantity: .00
Units: G
Recovered: .00
Oxygenate: Not reported